CLEAN ROOM CERTIFICATE OF PERFORMANCE

On this date: February 25 2025 The Cleanroom facilities of:

TELEDYNE MEMS

A business unit of Teledyne Digital Imaging, INC

Have been validated in accordance with the International Standard ISO 14644-1

in the operational state, with the following rooms meeting:

ROOMS: 410, 411, 412,413, 414, 415, 416, 417, 418, 419, 420, 421, 505, 507, 509 & 511 - **ISO CLASS 4 at 0.5 µm**

HALL BAY 2 and BAY 3 - **ISO CLASS 5 at 0.5 µm**
ROOM: 308, 501, 502 - **ISO CLASS 6 at 0.5 µm**

Validated by: Controlled Environment Technologies

299 Knottwood Road North Edmonton AB Canada T6K 2G5

Technician: Neil Hulleman Signature: _____